Turntide Smart Motor System™ Product Certifications



The Turntide Smart Motor System, along with each product within Turntide's HVAC retrofit solution, is designed and tested to meet a wide range of important safety certifications and industry standards from UL, CSA and IEC.

Certifications by Product



UL-CSA Standards

- UL 60335-2-40 Clause 30 Household and Similar Electrical Appliances Safety Part 2-40: Requirements for Electrical Heat Pumps, Air-Conditioners and Dehumidifiers
- UL 61800-5-1 Adjustable Speed Electrical Power Drive Systems - Part 5-1: Safety Requirements - Electrical, Thermal and Energy
- UL 61800-5-2 Adjustable Speed Electrical Power Drive Systems - Part 5-2: Safety Requirements - Functional
- CSA C22.2#274:2017 Ed.2 Adjustable Speed Drivers
- CSA C22.2#61800-5-2:2021 Ed.1 Adjustable Speed Electrical Power Drive Systems - Part 5-2: Safety Requirements -Functional

IEC

- IEC 61800-5-1 Adjustable Speed Electrical Power Drive Systems – Part 5-1: Safety Requirements – Electrical, Thermal and Energy
- IEC 61800-5-2 Adjustable Speed Electrical Power Drive Systems - Part 5-2: Safety Requirements - Functional
- IEC 61800-3 Adjustable speed electrical power drive systems -Part 3: EMC requirements and specific test methods



Turntide works with Intertek, which provides third-party validation with testing and certification.

An ETL mark can be found on all Turntide products to indicate compliance with the listed standards.

Overall System Standards

- UL 1004-1 Rotating Electrical Machines
- UL 1004-7 Electronically Protected Motors
- UL 1004-8 Inverter Duty Motors
- CSA C22.2 Motors and Generators
- CSA C22.2#77 Motors with Inherent Overheating
 Protection
- UL 60730-Automatic Electrical Controls for Household and Similar Use, Part 1: General Requirements (Supervisor)
- IEC 60034-1: 2017 (Ed.13.0) Rotating Machines Rating and Performance (Motors)
- IEC 60204-1: 2016 (Ed. 6.0) Rotating Machine Basic Safety (Motors)

Conformance

- Motor controller suitable for use in other environmental air handling spaces (plenums) in accordance with Section 300.22 (C) Other Spaces Used for Environmental Air (Plenums) of the National Electrical Code
- Required: Breaker rating 4xxVAC, 30A for
- Required: Fuse rating 6xxVAC, 30A, Class RK5
- Breakers must be UL489 SH3 listed



TURNTIDE TECHNOLOGIES

Our breakthrough technologies accelerate electrification and sustainable operations for energy-intensive industries

Turntide Technologies | 1295 Forgewood Avenue, Sunnyvale, CA 94089 | turntide.com | hvacmotorsales@turntide.com